

EXHIBIT Q

STATE OF CALIFORNIA

Edmund G. Brown Jr., Governor

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE

SAN FRANCISCO, CA 94102-3298



Advice Letter 2429-E-A

June 18, 2013

Clay Faber, Director
Regulatory Affairs
San Diego Gas and Electric
8330 Century Park Court, CP32C
San Diego, CA 92123-1548

**SUBJECT: SUBMISSION OF SDG&E'S FIRE-PREVENTION PLAN PURSUANT TO
OP 2 OF D.12-01-032**

Dear Mr. Faber:

Advice Letter 2429-E-A is approved, per Ordering Paragraphs listed in Resolution E-4576, effective May 23, 2013.

Sincerely,

A handwritten signature in black ink that reads "Edward F. Randolph".

Edward F. Randolph, Director
Energy Division



Clay Faber - Director
Regulatory Affairs
8330 Century Park Court
San Diego, CA 92123-1548

Tel: 858.654.3563
Fax: 858.654.1788
cfaber@semprautilities.com

June 3, 2013

ADVICE LETTER 2429-E-A
(U902-E)

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

**SUBJECT: SUPPLEMENTAL FILING -- SUBMISSION OF SDG&E'S FIRE-
PREVENTION PLAN PURSUANT TO ORDERING PARAGRAPH (OP) 2 OF
DECISION (D) 12-01-032 AND OP 2 OF RESOLUTION E-4576**

San Diego Gas & Electric Company ("SDG&E") hereby submits to the California Public Utilities Commission ("CPUC" or "Commission") SDG&E's Fire-Prevention Plan, as shown in Attachment A, as required by OP 2 of D.12-01-032 and OP 2 of Resolution E-4576. This supplemental AL replaces AL 2429-E in its entirety.

BACKGROUND

The Commission initiated Rulemaking (R.) 08-11-005 on November 6, 2008, entitled "Order Instituting Rulemaking to Revise and Clarify Commission Regulations Relating to the Safety of Electric Utility and Communications Infrastructure Provider Facilities." The Rulemaking was divided into three phases. Phase 1 focused on fire-prevention measures that could be implemented in time for the 2009 fall fire season in southern California. Phase 1 concluded with the issuance of D.09-08-029 on August 20, 2009. In Phase 2, the Commission considered additional new measures to reduce fire hazards associated with overhead power-line facilities and communication facilities. Phase 2 concluded with the issuance of D.12-01-032 on January 12, 2012. In D.12-01-032, the Commission also established Phase 3 of the proceeding for the purpose of developing and adopting additional safety measures and fire-threat maps. A schedule for facilitated workshops in Phase 3 of this proceeding was issued on November 20, 2012.

SDG&E filed Advice Letter (AL) 2336-E on March 12, 2012 to revise Electric Rule 11 (Discontinuance of Service) and Electric Rule 16 (Service Extensions) pursuant to OP 7 of D.12-01-032 to include language that the electric utility may shut-off power to a property owner who obstructs access to the utility's overhead power-line facilities located on the owner's property for vegetation management purposes. AL 2366-E was approved by the Commission via Resolution E-4493 on September 14, 2012.

Public Utilities Commission

2

June 3, 2013

DISCUSSION

OPs 2, 4, and 5 of D.12-01-032 direct each investor-owned electric utility to prepare a fire-prevention plan and file and serve a copy of this plan by December 31, 2012 via a Tier 1 compliance Advice Letter. These plans are required to address situations where all three of the following conditions occur simultaneously:

- (i) 3-second wind gusts exceed the structural or mechanical design standards for the affected overhead power-line facilities,
- (ii) these 3-second gusts occur during a period of high fire danger, and
- (iii) the affected facilities are located in a high fire-threat area

Additionally, the fire-prevention plans required by D.12-01-032 shall specify (i) how the investor-owned electric utility will identify the occurrence of 3-second wind gusts that exceed the structural or mechanical design standards for overhead power-line facilities; and (ii) the countermeasures the utility will implement to mitigate the threat of power-line fire ignitions.

On December 7, 2012 SDG&E filed AL 2429-E to comply with the requirements of D.12-01-032. On May 23, 2013, the Commission issued Resolution E-4576 approving SDG&E's AL 2429-E with modifications. OP 2 of Resolution E-4576¹ requires SDG&E to revise its FPP to clarify that proactive power shut off as a fire prevention measure will only be considered in accordance with OP 6 of D.12-01-032. Or, as an alternate, E-4576 states that the phrase may be deleted.

Additionally, SDG&E herein modifies the language in the table on page 25 of its FPP, which contains the phrase "All reclosers will be turned off". SDG&E agrees with the Resolution's suggestion to clarify this language; hence, it has been revised to read, "All reclosing functions will be de-activated", meaning the power stays on until the recloser contact opens at its setting and stays open until closed by an operator.

Attached hereto, as Attachment A, is SDG&E's fire-prevention plan as required by OP 2 of D.12-01-032. SDG&E has modified the language in the table on page 25 as noted above and deleted the phrase – "These reclosers provide SDG&E's operators with the ability to intervene, whenever and wherever the risk of fire is high, to deenergize selected segments of the SDG&E system until field operations can confirm that it is safe to re-energize a line *or circuit*." – from page 15, Section 4 pursuant to OP 2 of Resolution E-4576.

EFFECTIVE DATE

Pursuant to Ordering Paragraph 2 of D.12-01-032, Ordering Paragraph 2 of Resolution E-4576, and GO 96-B, SDG&E believes that this filing is subject to Energy Division disposition and should

¹ OP #2 states: "SDG&E's AL is conditionally approved subject to the following: within 10 days of effectiveness of this resolution, SDG&E shall clarify its statement in the FPP on Page 15 that "These reclosers provide SDG&E's operator with the ability to intervene, whenever and wherever the risk of fire is high, to de-energize selected segments of the SDG&E system ..." A statement to the effect that this planned action would only be considered after complying with the requirements of D. 12-01-032, OP 6 must be added. As an alternate the phrase may be deleted."

Public Utilities Commission

3

June 3, 2013

be classified as Tier 1 (effective pending disposition). SDG&E respectfully requests that this filing become effective on June 3, 2013, the date filed.

PROTEST

Anyone may protest this Advice Letter to the California Public Utilities Commission. The protest must state the grounds upon which it is based, including such items as financial and service impact, and should be submitted expeditiously. The protest must be made in writing and must be received no later than June 23, 2013, which is within 20 days of the date this Advice Letter was filed with the Commission. There is no restriction on who may file a protest. The address for mailing or delivering a protest to the Commission is:

CPUC Energy Division
Attention: Tariff Unit
505 Van Ness Avenue
San Francisco, CA 94102

Copies of the protest should also be sent via e-mail to the attention of the Energy Division at EDtariffUnit@cpuc.ca.gov. A copy of the protest should also be sent via both e-mail and facsimile to the address shown below on the same date it is mailed or delivered to the Commission.

Attn: Megan Caulson
Regulatory Tariff Manager
8330 Century Park Court, Room 32C
San Diego, CA 92123-1548
Facsimile No. (858) 654-1879
E-mail: MCaulson@semprautilities.com

NOTICE

A copy of this filing has been served on the utilities and interested parties shown on the attached list including parties in R.08-11-005 and A.08-12-021 by either providing them a copy electronically or by mailing them a copy hereof, properly stamped and addressed.

Address changes should be directed to SDG&E Tariffs by facsimile at (858) 654-1879 or by e-mail at SDG&ETariffs@semprautilities.com.

CLAY FABER
Director - Regulatory Affairs

(cc list enclosed)

CALIFORNIA PUBLIC UTILITIES COMMISSION**ADVICE LETTER FILING SUMMARY
ENERGY UTILITY****MUST BE COMPLETED BY UTILITY (Attach additional pages as needed)**Company name/CPUC Utility No. **SAN DIEGO GAS & ELECTRIC (U 902)**

Utility type:

☒ ELC☐ GAS☐ PLC☐ HEAT☐ WATERContact Person: Megan CaulsonPhone #: (858) 654-1748E-mail: MCaulson@SempraUtilities.com**EXPLANATION OF UTILITY TYPE**

ELC = Electric

GAS = Gas

PLC = Pipeline

HEAT = Heat

WATER = Water

(Date Filed/ Received Stamp by CPUC)

Advice Letter (AL) #: 2429-E-ASubject of AL: Supplemental Filing -- Submission of SDG&E's Fire-Prevention Plan Pursuant to Ordering Paragraph 2 of Decision 12-01-032 and Ordering Paragraph 2 of Resolution E-4576Keywords (choose from CPUC listing): ComplianceAL filing type: ☐ Monthly ☐ Quarterly ☐ Annual ☒ One-Time ☐ Other

If AL filed in compliance with a Commission order, indicate relevant Decision/Resolution #:

D.12-01-032 and Resolution E-4576

Does AL replace a withdrawn or rejected AL? If so, identify the prior AL

N/ASummarize differences between the AL and the prior withdrawn or rejected AL¹:N/A

Does AL request confidential treatment? If so, provide explanation:

Resolution Required? ☐ Yes ☒ NoTier Designation: ☒ 1 ☐ 2 ☐ 3Requested effective date: 6/3/2013No. of tariff sheets: 0Estimated system annual revenue effect (%): N/AEstimated system average rate effect (%): N/A

When rates are affected by AL, include attachment in AL showing average rate effects on customer classes (residential, small commercial, large C/I, agricultural, lighting).

Tariff schedules affected:

Service affected and changes proposed¹: N/APending advice letters that revise the same tariff sheets: N/A**Protests and all other correspondence regarding this AL are due no later than 20 days after the date of this filing, unless otherwise authorized by the Commission, and shall be sent to:**

CPUC, Energy Division

Attention: Tariff Unit

505 Van Ness Ave.,

San Francisco, CA 94102

mas@cpuc.ca.gov and jnj@cpuc.ca.gov

San Diego Gas & Electric

Attention: Megan Caulson

8330 Century Park Ct, Room 32C

San Diego, CA 92123

mcaulson@semprautilities.com

¹ Discuss in AL if more space is needed.

General Order No. 96-B
ADVICE LETTER FILING MAILING LIST

cc: (w/enclosures)

Public Utilities Commission

DRA

S. Cauchois
J. Greig
W. Scott

Energy Division

P. Clanon
S. Gallagher
H. Gatchalian
D. Lafrenz
M. Salinas

CA. Energy Commission

F. DeLeon
R. Tavares

Alcantar & Kahl LLP

K. Harteloo

American Energy Institute

C. King

APS Energy Services

J. Schenk

BP Energy Company

J. Zaiontz

Barkovich & Yap, Inc.

B. Barkovich

Bartle Wells Associates

R. Schmidt

Braun & Blaising, P.C.

S. Blaising

California Energy Markets

S. O'Donnell
C. Sweet

California Farm Bureau Federation

K. Mills

California Wind Energy

N. Rader

CCSE

S. Freedman
J. Porter

Children's Hospital & Health Center

T. Jacoby

City of Chula Vista

M. Meacham
E. Hull

City of Poway

R. Willcox

City of San Diego

J. Cervantes
G. Loneragan
M. Valerio

Commerce Energy Group

V. Gan

Constellation New Energy

W. Chen

CP Kelco

A. Friedl

Davis Wright Tremaine, LLP

E. O'Neill
J. Pau

Dept. of General Services

H. Nanjo
M. Clark

Douglass & Liddell

D. Douglass
D. Liddell
G. Klatt

Duke Energy North America

M. Gillette

Dynegy, Inc.

J. Paul

Ellison Schneider & Harris LLP

E. Janssen

Energy Policy Initiatives Center (USD)

S. Anders

Energy Price Solutions

A. Scott

Energy Strategies, Inc.

K. Campbell
M. Scanlan

Goodin, MacBride, Squeri, Ritchie & Day

B. Cragg
J. Heather Patrick
J. Squeri

Goodrich Aerostructures Group

M. Harrington

Hanna and Morton LLP

N. Pedersen

Itsa-North America

L. Belew

J.B.S. Energy

J. Nahigian

Luce, Forward, Hamilton & Scripps LLP

J. Leslie

Manatt, Phelps & Phillips LLP

D. Huard
R. Keen

Matthew V. Brady & Associates

M. Brady

Modesto Irrigation District

C. Mayer

Morrison & Foerster LLP

P. Hanschen

MRW & Associates

D. Richardson

OnGrid Solar

Andy Black

Pacific Gas & Electric Co.

J. Clark
M. Huffman

S. Lawrie

E. Lucha

Pacific Utility Audit, Inc.

E. Kelly

R. W. Beck, Inc.

C. Elder

School Project for Utility Rate Reduction

M. Rochman
Shute, Mihaly & Weinberger LLP

O. Armi

Solar Turbines

F. Chiang

Sutherland Asbill & Brennan LLP

K. McCrea

Southern California Edison Co.

M. Alexander
K. Cini

K. Gansecki

H. Romero

TransCanada

R. Hunter

D. White

TURN

M. Florio

M. Hawiger

UCAN

M. Shames

U.S. Dept. of the Navy

K. Davoodi

N. Furuta

L. DeLacruz

Utility Specialists, Southwest, Inc.

D. Koser

Western Manufactured Housing

Communities Association

S. Dey

White & Case LLP

L. Cottle

Interested Parties

R.08-11-005

A.08-12-021

Attachment A
SDG&E Supplemental Advice Letter 2429-E-A
June 3, 2013
Fire-Prevention Plan

SAN DIEGO GAS & ELECTRIC COMPANY

FIRE PREVENTION PLAN



JUNE 3, 2013

TABLE OF CONTENTS

I.	Executive Summary	4
II.	Minimizing Sources of Ignition	8
A.	Mapping the High-Risk Fire Areas in the SDG&E Service Territory	8
1.	Mapping the Fire Threat Zone	8
2.	Mapping the Highest Risk Fire Area.....	9
B.	Fire-Hardening the SDG&E System	11
1.	Design and Construction Standards	12
2.	Wood-to-Steel Program	13
3.	Undergrounding Line Segments and Facilities	13
4.	Automated Reclosers	15
5.	Fire Detection and Fire Alerts.....	16
6.	Testing and Deploying Emerging Technologies	16
7.	Facility Inspection and Repair Program	17
8.	Oversight of Activities in the Rural Areas	18
III.	Operational Practices for Reducing the Risk of Ignition.....	20
A.	System Management: Quality Assurance and Quality Control.....	20
B.	Enhanced Vegetation Management and Clearance Program	21
C.	Coordination with Communications Infrastructure Providers	22
D.	Workforce Training and Field Practices	23
IV.	Mitigating the Threat of Fire: Awareness and Readiness	24
A.	Situational Awareness	24
B.	The SDG&E Emergency Operations Center	26
C.	The Fire Potential Index.....	27
D.	Crew Mobilization and Deployment Strategy	30
E.	Field Patrols	31
V.	Fire Suppression and Recovery	31
A.	Fire Coordination Personnel.....	31
B.	Firefighting Assets and Resources	32
1.	Utility Wildfire Prevention Team	32

2.	Aviation Services Department.....	32
3.	The Industrial Fire Brigade	33
4.	Miscellaneous Assets	33
C.	Recovery Activities	34
VI.	Community Outreach and Public Awareness	34
A.	Fire Safety Stakeholder Council.....	34
B.	Partnering with Firefighting Agencies	35
C.	Community Partnerships	35
D.	Fire Preparedness Website	37
E.	Fire Mitigation Funds	37
Appendix A - 2012 Map of SDG&E Fire Threat Zone, Highest Risk Fire Area, and Meteorologist Network.....		37

I. Executive Summary

San Diego Gas & Electric Company ("SDG&E") provides this Fire Prevention Plan in compliance with Ordering Paragraphs 2, 4 and 5 of Commission Decision 12-01-032 (the "*Fire Safety Order*"). Those Ordering Paragraphs provided the following directions:

2. Each investor-owned electric utility in Southern California shall (i) prepare a fire-prevention plan, and (ii) file and serve a copy of its fire-prevention plan by December 31, 2012, via a Tier 1 compliance advice letter.
4. The fire-prevention plans required by today's decision shall address situations where all three of the following conditions occur simultaneously: (i) three-second wind gusts exceed the structural or mechanical design standard for the affected overhead power-line facilities, (ii) these three-second gusts occur during a period of high fire danger, and (iii) the affected facilities are located in a high fire-threat area.
5. The fire-prevention plans required by today's decision shall specify (i) how the investor-owned electric utility will identify the occurrence of three-second wind gusts that exceed the structural or mechanical design standards for overhead power-line facilities; and (ii) the countermeasures the utility will implement to mitigate the threat of power-line fire ignitions.

The SDG&E Fire Prevention Plan provides a comprehensive inventory of the organizational and operational activities SDG&E undertakes in order to address the risk of fire in the SDG&E service territory. The catastrophic wildfires which devastated San Diego County in 2007, unprecedented in their sheer magnitude and horrific effects, resulted in a profound, enduring culture change reflected throughout the Applicants' utility operations, system and facilities, organization, and corporate goals and objectives. As evidenced in this Fire Prevention Plan, SDG&E has a company-wide, single-minded focus on addressing and minimizing wildfire-related risks to public health, safety and welfare. SDG&E's commitment to fire safety, prevention, mitigation, control, and recovery is a central tenet of our corporate culture. We take a leadership role in addressing fire threats in the communities we serve and freely share our personnel, resources, information, communications facilities, and/or fire-defense assets so as to enhance the capabilities of our local communities to defend against any repeats of the catastrophic wildfire events recently experienced in southern California.

The SDG&E Fire Prevention Plan reflects a broad range of activities performed throughout the SDG&E organization. The Fire Prevention Plan is subject to the direct supervision of senior management, and its effectiveness is a performance measure for many SDG&E employees, some of whom are directly or indirectly responsible for contributing to and/or performing the activities described in the Fire Prevention Plan. The SDG&E Fire Prevention Plan begins with system design, construction, operation, maintenance, inspection, and repair activities aimed at significantly reducing the potential for SDG&E facilities to become the source of ignition for a fire. Nevertheless, the ubiquity of our facilities and the range of operating conditions faced in the SDG&E service territory present some risk that our facilities, no matter how diligent or conservative our practices, might become the original or contributing source of ignition for a fire. To address this risk, SDG&E has implemented extensive operational programs designed to monitor the system closely whenever and wherever the threat of fire is elevated so that, in the event of an ignition, the threats to the public safety from fire are quickly abated or mitigated as fully and quickly as possible. These programs include gathering and analyzing the data from SDG&E's 145 weather stations, the third-largest private meteorological network in the country, to determine where and when the threat of fire will present itself, which in turn facilitates the immediate organization and implementation of the SDG&E response appropriate to the threat.

SDG&E monitors all wildland fires in its service territory. These are fires that burn vegetation and are capable of propagation and may also threaten SDG&E facilities or may involve an SDG&E asset.

SDG&E's Fire Prevention Plan also includes firefighting and fire-recovery activities. In the event fire conditions threaten public safety or SDG&E facilities or may involve an SDG&E asset, SDG&E will mobilize an appropriate range of resources including trained firefighting assets, communications capabilities, data and information collection, and command facilities, to address fire threats and assure the earliest possible recovery from a fire event in the affected communities.

Finally, the SDG&E Fire Prevention Plan is a "living document". In coordination with our many stakeholders, community leaders and the public, SDG&E shares and vets the Fire Prevention Plan so as to assure its continuous improvement and maximum effectiveness. Community outreach and communications are also important aspects of the fire prevention, mitigation and recovery activities included in the Fire Prevention Plan. As SDG&E has shared and vetted the Fire

Prevention Plan with stakeholders and the public, the process has created a natural audience for disseminating information before, during and after conditions related to fires and the threat of fire. This audience is an important part of the communications chain used to broadcast threat and event information.

The activities described in SDG&E's Fire Prevention Plan have earned SDG&E various accolades for planning and performance. Beginning in 2005, SDG&E has been ranked "Best in the West" in reliability by PA Consulting Group, earning their regional ReliabilityOne award for seven consecutive years. SDG&E also received PA Consulting Group's National Award for Outstanding Reliability Performance in 2010.¹ In 2008, SDG&E received PA Consulting Group's award for Outstanding Response to a Major Outage Event for our response to the 2007 wildfires. SDG&E has also been designated as a Tree Line USA utility by the National Arbor Day Foundation in recognition of our "best practices in utility arboriculture".² More recently, SDG&E received the Fire Safe Council Partner of the Year award for demonstrated leadership with community defensible space funding.³ These awards validate our efforts to assure our Fire Prevention Plan is best in class and grounded in the purposes we share with the communities we serve.

Although SDG&E measures and records data such as the "three second gusts" this specific information is not used as the single data point upon which to develop and put in place the many programs that SDG&E employs in the overall prevention of fire within its service territory which is described in this SDG&E Fire Prevention Plan.

The goals and activities included in the SDG&E Fire Prevention Plan focus on a comprehensive and integrated assessment of the risks of fire posed by SDG&E's overhead electric system. This assessment involves an assessment of SDG&E's equipment and facilities, weather conditions, the density and condition of potential fuels such as vegetation, and the potential threat to public safety, health and welfare using value at-risk measures, as depicted in the graphic below.

¹ Information regarding PA Consulting Group's international consulting practice and best practices awards program for the electric utility industry can be found at the firm's public website and the following address: <http://www.paconsulting.com/industries/energy/merchant-utility/improving-performance-of-utility-through-benchmarking/polaris/r1-and-s1-awards/>.

² Information regarding the National Arbor Day Foundation and the The Tree Line USA program, operated in conjunction with the National Association of State Foresters, can be found at the Foundation's public website and the following address: <http://www.arborday.org/programs/treelineusa/summary.cfm>.

³ Information regarding the Fire Safe Council (California Chapter), its extensive membership and Partner of the Year Award can be found at the Council's public website and the following address: <http://www.firesafecouncil.org/about/index.cfm>.



SDG&E's commitment to fire safety, prevention, mitigation, control, and recovery is a central tenet of our corporate culture. With this overarching view of fire risk assessment in mind, SDG&E presents the activities comprising its Fire Prevention Plan.

II. Minimizing Sources of Ignition

The SDG&E Fire Prevention Plan is founded upon the goal of minimizing the probability that the various components of its sixty-nine-kilovolt transmission and twelve kilovolt distribution system might become the original or contributing source of ignition for a fire. SDG&E evaluated the prudent, cost-effective changes and improvements to its physical assets that could and should be made in order to meet this objective and implemented a preventative construction and maintenance plan consistent with these evaluations.

A. Mapping the High-Risk Fire Areas in the SDG&E Service Territory

SDG&E has performed and completed extensive mapping of its service territory to identify those areas at greatest risk to the occurrence of uncontrolled fires. Through these efforts, SDG&E identified two sets of geographic areas based on the potential risk of fire in the area and the threat to the public safety posed by fire. These two areas are known as the "Fire Threat Zone" and the "Highest Risk Fire Area". Generally, the Fire Threat Zone includes the geographic areas most prone to wildfire due to local environmental conditions and features, and the Highest Risk Fire Area includes areas within the Fire Threat Zone where the risk of fire is the greatest.

1. Mapping the Fire Threat Zone

As part of its response to Commission Rulemaking 08-11-005, SDG&E mapped its service territory to identify those areas where, due to local environmental conditions and features, the potential for wildfire was relatively high. This Fire Threat Zone would be used to identify the areas where enhancements to rules, regulations and standards could reduce the potential for electric systems and facilities to ignite fires and thereby increase public safety and system reliability.

The Fire Threat Zone mapping exercise followed several key, objective principles. First, the Fire Threat Zone was defined using parameters that would result in relatively constant boundaries not subject to continuous change and revision. This resulted in the use of criteria that tended to be conservative, *i.e.*, more inclusive than exclusive, so that the Fire Threat Zone would describe the complete domain where the potential for wildfire was relatively high. Additionally, the Fire Threat Zone map would need to be easily understood by key personnel and users, whether utility or other public officials, who might rely upon it in performing their job responsibilities.

In performing the mapping task, SDG&E began with the vegetation data developed and maintained by the California Department of Forestry and Fire Protection ("CalFIRE"). These data were available on the CalFIRE Fire and Resource Assessment Program ("FRAP") website. Using this data, SDG&E mapped the Fire Threat Zone in its service territory. This zone encompasses most of the vegetated rural areas in the Counties of San Diego and Orange. Compared to the Highest Risk Fire Area described below, the Fire Threat Zone includes areas where the density of vegetation is relatively low. The FRAP maps describe the fire risks in certain areas as "low", "moderate", "high", "very high", and "extreme". Generally, the Fire Threat Zone include all of the areas described in the FRAP maps as "extreme" and "very high" risk and some portion of the areas described as "high" risk. In shaping the Fire Threat Zone, SDG&E also applied its knowledge of its service area and internally developed high-resolution weather data and histories.

Because SDG&E personnel will use the Fire Threat Zone map for various purposes, it was important to make the Fire Threat Zone map easy to use and understand. One particular adjustment made by SDG&E to the raw data upon which the map was based was to create a contiguous Fire Threat Zone, rather than create a multitude of "pockets" of high risk. The original data created a mosaic of areas of varying degrees of risk – such a map would have been difficult to interpret and use. As an example, based purely on the raw weather and vegetation data, there would have been areas where the risk of fire would have been designated as "low", "very high", and "low" again along a one-mile stretch of road. Rather than include and parse anomalies, SDG&E adjusted the shape of the Fire Threat Zone to normalize the design, construction, operations, maintenance, and inspection activities across larger areas. This resulted in the inclusion of some lower-risk areas in the Fire Threat Zone and, in a few cases, the exclusion of some isolated higher-risk areas from the Threat Zone. The resulting color-coded Fire Threat Zone map is attached to this Fire Prevention Plan as Appendix A.

The Commission has authorized SDG&E to use its Fire Threat Zone map until such time as the Commission issues its final rules and regulations governing the development and maintenance of fire-threat maps as part of Phase 3 of Rulemaking 08-11-005. SDG&E is participating in that proceeding and will update its Fire Threat Zone map pursuant to the further direction of the Commission.

2. Mapping the Highest Risk Fire Area

The Highest Risk Fire Area represents those areas within the Fire Threat Zone where local environmental conditions and features combine to create the highest risk of fire in the SDG&E service territory. SDG&E's Fire Coordinators, a team of in-house experts trained and experienced in fire behavior, fire prevention and firefighting, drafted the initial Highest Risk Fire Area map in 2008. Using Geographic Information System software, SDG&E's experts identified areas where the combination of relatively dense vegetation, relatively high winds, and development (e.g., homes, hospitals, schools, and other community assets) presented the highest risks of fire, property losses and injury from fire. Thus, the Highest Risk Fire Area map identifies the areas marked by an overlap of (1) the "highest risk vegetation", *i.e.*, where the vegetation was relatively dense and in close proximity to housing, business and/or community development,⁴ and (2) locations prone to high winds.

As with the Fire Threat Zone map, SDG&E utilized the FRAP data and maps available from CalFIRE to determine the level of vegetation likely to exist in specific areas of the Fire Threat Zone. Areas prone to high winds were identified using historical data from weather stations located throughout the SDG&E service territory. This included the use of data from SDG&E's private network of weather stations, now numbering 145 in what is the third-largest private network of weather stations in the country. The data were used to identify locations where there was a reasonable probability that wind speeds would exceed fifty miles-per-hour (50 mph) under the "Santa Ana" wind conditions usually experienced during the late summer and early fall in southern California. Finally, SDG&E adjusted the Highest Risk Fire Area map to reflect our own knowledge and information regarding conditions in our service territory. For example, where no SDG&E equipment was located in the area, the area was excluded from the Highest Risk Fire Area.

The Highest Risk Fire Area maps are reviewed at the beginning of each year and adjusted to reflect environmental conditions expected to be present during the coming year's fire season, typically the late summer and early fall seasons of each year. For example, fire perimeters and other fire protection measures are updated annually and reflected in the Highest Risk Fire Area maps. In addition, the methodologies used to develop the Highest Risk Fire Area map are reviewed and modified to ensure that lessons learned are incorporated into the map. As an

⁴ In assessing fire risks and prioritizing fire prevention activities, SDG&E considers the potential that an uncontrolled fire will threaten members of the public and/or property. Based on expert analyses provided by the Fire Coordinator team, SDG&E considers the potential path a wildfire is likely to take and prioritizes its activities along those corridors where the risk to life and property are greatest.

example, SDG&E assures that the Highest Risk Fire Area includes areas where there are data indicating a coincidence of high winds and dense vegetation may be present; formerly, SDG&E focused solely on the density of vegetation (*i.e.*, fuel). The resulting color-coded Highest Risk Fire Area map is attached to this Fire Prevention Plan as Appendix A.

As noted above, the Commission has authorized SDG&E to use its Highest Risk Fire Area map until such time as the Commission issues its final rules and regulations governing the development and maintenance of fire-threat maps as part of Phase 3 of Rulemaking 08-11-005. SDG&E is participating in that proceeding and will update its Highest Risk Fire Area map pursuant to the further direction of the Commission.

B. Fire-Hardening the SDG&E System

In providing this Fire Prevention Plan, SDG&E takes note that the Commission's order focuses specifically on the measures taken by SDG&E related to the occurrence of "three-second wind gusts...that may exceed the structural or mechanical design standards for overhead power-line facilities." In reviewing the SDG&E Fire Prevention Plan, the Commission should be aware that SDG&E organizes its activities around addressing the threat of fire posed by various conditions and, in particular, on reducing the potential that SDG&E's facilities or operations might provide an original or contributing source of ignition for a fire. As the Fire Safety Order correctly anticipates, forecasted and ambient wind conditions, especially when high winds combine with the hot, dry conditions typically experienced during the late summer and early fall seasons in southern California, are an important factor in assessing and addressing fire threats.

Three-second gusts represent a "measurement standard" rather than an independent "fire condition". That is, the weather instruments relied upon by SDG&E for measuring wind conditions are designed and calibrated to measure, record and report wind speeds across ten-minute periods – the average of the wind speeds recorded across any single ten-minute period is reported as the "sustained wind". In computing wind data for each ten-minute period, wind speeds are measured across three-second intervals and the highest wind speed reached during any three-second interval within any ten-minute period is separately recorded as the highest "gust" for the period. With respect to assessing and responding to the potential threat of fires, SDG&E takes potential and actual wind speeds into account, both as to sustained winds and gusts. Although both sustained wind speeds and gusts are considered, SDG&E's Fire Prevention Plan programs and activities are not designed around either wind

measure. Rather, both are considered within a full range of inputs related to Fire Prevention Plan programs and activities.⁵ The three-second interval by which “gusts” are measured is not, then, an independent operational planning standard or the focus of facility design and construction standards. Thus, SDG&E plans for, monitors and adjusts operations for wind speeds “that may exceed the structural or mechanical design standards for overhead power-line facilities”, but SDG&E’s safety-related activities cannot be said to address the potential for strong wind *gusts* as a standalone criterion.

Using the Fire Threat Zone and Highest Risk Fire Area maps, SDG&E evaluated the prudent and cost-effective system improvements it could make to its transmission and distribution system which would reduce the potential for SDG&E’s facilities in the Fire Threat Zone and Highest Risk Fire Area to provide the source of ignition for a fire. In part, this evaluation was performed in conjunction with the Commission’s Rulemaking 08-11-005 – during Phase 1 of the proceeding, the Commission modified, with SDG&E’s full support, various design, construction, maintenance, and inspection standards consistent with reducing the threat of fire posed by overhead electric and communications facilities.

1. Design and Construction Standards

To reflect the more stringent design and construction standards adopted by the Commission and so as to improve the performance of the SDG&E system in terms of meeting fire-prevention goals, the SDG&E Facilities Design Manual was modified to include an entirely new section aimed at providing guidance for hardening circuits against the risk of fire. These modifications include both proactive measures designed to reduce the incidence of ignitions and reactive measures by which SDG&E can respond to the threat of fires and mitigate the spread of fires. As an example, various sections in the SDG&E Facilities Design Manual are undergoing revision to provide for smaller fuses – these fuses are better equipped to sense low-grade faults which are more common in rural settings.

SDG&E is also an aggressive advocate for modernizing those portions of the Commission’s General Order 95 which provide the rules and regulations

⁵ As an example, among the non-environmental factors taken into account as SDG&E evaluates the threat of fire is whether firefighting assets are available or unavailable. Where local firefighting assets might have been previously deployed to a distant locale to fight an existing fire, SDG&E would be more conservative in assessing the actions it might take to abate or mitigate the potential threats within its service area. Winds would be a factor, but not the single determining factor under this circumstance, in deciding SDG&E’s response to the local threat of fire.

governing the design and construction of overhead electric and communications facilities. SDG&E is vetting the concept of "Load Factor and Resistance Design" and a new "High Wind Loading District" with stakeholders in Phase 3 of the Commission's Rulemaking 08-11-005 with the objective of improving General Order 95's focus on fire-safety and system-reliability objectives. Fire safety begins with the design and construction standards pursuant to which utility facilities are designed, built and operated, so improving these regulations will provide the foundation for assuring that facilities built in the future will be stronger and safer than those built under prior versions of the rules.

2. Wood-to-Steel Program

Of major significance is SDG&E's program to undertake a large-scale replacement of wood poles used in those portions of the SDG&E sixty-nine kilovolt transmission and twelve kilovolt distribution system located in the Fire Threat Zone and Highest Risk Fire Area, substituting steel poles in their place. These poles are designed to withstand working loads under the stress of eighty-five mile-per-hour (85 mph) wind speeds. To date, SDG&E has installed over 2,000 of these new steel poles in the Fire Threat Zone and plans on further investment to aggressively continue to replace wood distribution and transmission poles with steel poles. These new steel pole facilities are being installed in conjunction with the application of heavier conductors which allow SDG&E to increase the spacing between lines beyond the requirements of Commission General Order 95, resulting in a decrease in the likelihood live lines will come into contact with one another or arc after being struck by flying debris. In addition, SDG&E's current design standards now reflect the use of steel poles over wood poles in the Fire Threat Zone.

3. Undergrounding Line Segments and Facilities

In 2011, SDG&E formed a technical team with expertise in the undergrounding of distribution systems and facilities. The team evaluated the undergrounding of various circuits, segments, elements, and equipment located in the Highest Risk Fire Area. These experts provided senior management with an understanding of the potential for undergrounding portions of the overhead system in order to mitigate the risk of fire. The team's initial analysis identified ten (10) undergrounding projects where the potential for mitigating fire risks was promising. These projects were studied as test cases so that the team could identify and possibly resolve complexities associated with undergrounding SDG&E's facilities in the Fire Threat Zone and Highest Risk Fire Area.

As of October 2012, two of the ten original undergrounding projects had completed construction, one was under construction, and the remaining seven projects were in the design phase. The seven projects undergoing design were relatively larger and/or more complex, and lessons learned from the other three projects are being reflected in the project design. As examples, permitting, completion of environmental reviews and the acquisition of rights-of-way have proven to be more lengthy and complex compared to undergrounding projects performed under SDG&E's Rule 20A and 20SD programs. Accommodations and changes to the projects are being made so as to take these factors into consideration.

a. Special Case: The Cleveland National Forest Powerline Replacement Project

SDG&E currently operates and maintains a network of electric facilities located within and traversing the Cleveland National Forest. In connection with its prior application for a "Master Special Use Permit" to operate and maintain these facilities, SDG&E has worked closely with the U.S. Forest Service to develop a series of projects and activities aimed at increasing safety and reliability of existing electric facilities within and near the Forest.⁶

The activities and projects planned for the Forest will replace existing electric infrastructure currently serving the Forest Service, emergency service facilities (fire, communication and other), campgrounds, homes, businesses, and various customers within the Forest and surrounding areas. The work plan contemplates the replacement of several existing twelve kilovolt and sixty-nine kilovolt electric facilities spread throughout an area encompassing approximately 880 square miles in eastern San Diego County. In addition, various segments will be reconfigured: these reconfigurations include undergrounding of certain segments, realignments to less risky areas, placing certain distribution facilities on transmission towers and common poles, and other structural and engineering enhancements. These activities and projects are intended and designed to increase fire safety and system reliability. Importantly, the overall project encompasses the fire-hardening of transmission and distribution facilities in the Forest through the replacement of over 150 miles of older lines, including existing electric lines located within the Forest and extending beyond the Forest

⁶ Collectively, these projects and activities are commonly referred to as the "CNF Electric Safety and Reliability Project".

boundaries. The overall project includes operational components complementing SDG&E's Community Fire Safety Program, which in turn includes community outreach, new fire prevention measures and enhanced emergency response.

The project design was based on various recommendations addressing fire prevention and the Forest's environmental and visual values. Using an analytical matrix reflecting elements of fire risks and environmental concerns, SDG&E and the Forest Service collaborated to determine which sections of the system should be upgraded. Each segment required a custom solution based on many factors, including the location of the entity being served by the distribution system, the topography of the land, and various biological, cultural and environmental factors.

Most of the construction activities proposed in connection with the overall project require review and approval by the Forest Service, the Commission, and various other public agencies. The Forest Service and Commission are expected to lead and conduct a joint federal-state environmental review. Once approved, the individual construction projects will likely occur in phases, spread over time and distance so as to minimize impacts and disruptions in the Forest and surrounding areas.

4. Automated Reclosers

As part of its Community Fire Safety Program, SDG&E has undertaken one of the nation's largest deployments of state-of-the-art pulse reclosers, focusing heavily on the Fire Threat Zone and Highest Risk Fire Area. This equipment allows SDG&E to operate its system with significantly reduced energy flows during reclosing operations and be able to sectionalize various elements of its distribution system to better manage system operations and reliability. These pulse reclosers and other Supervisory Controlled and Data Acquisition ("SCADA") controlled reclosers are managed remotely by SDG&E Distribution System Operators via the SDG&E Smart Grid Network. In addition, SDG&E has implemented more sensitive relay settings to all SCADA reclosers in the Highest Risk Fire Area. These sensitive relay settings provide very fast clearing for distribution circuits and are implemented via SCADA allowing for real-time adjustments triggered by adverse weather conditions. Importantly, these reclosers are tied to fire-related operational schemes and programs described later in this Fire Prevention Plan.

5. Fire Detection and Fire Alerts

In addition to improving the SDG&E system, SDG&E is leveraging its assets to address fire threats. Along these lines, SDG&E has placed high-visibility, high-resolution rotating cameras on twenty-nine (29) key towers along those portions of the newly constructed Sunrise Power Link located in the Fire Threat Zone and Highest Risk Fire Area.⁷ The cameras were activated in September 2012 and provide around-the-clock live video coverage of the transmission line and the areas immediately adjacent to the towers. The cameras can be controlled remotely, can rotate a full 360 degrees, and provide footage to the system operations group. Coupled with an advanced centralized smoke-detection algorithm, the video system greatly enhances SDG&E's early fire-detection and -warning capabilities.

SDG&E is also collaborating with the staff at the University of California at San Diego responsible for the operation of the San Diego High-Performance Wireless Research and Education Network. This high-speed wireless data network is designed to connect hard-to-reach areas in remote environments and provide real-time data; the network includes earthquake sensors and mountaintop cameras, the latter of which have become a part of the emerging early fire-detection and fire-warning system being deployed in the San Diego backcountry. In addition, SDG&E has also engaged multiple vendors specializing in early fire detection systems and will continue to work with these vendors to develop new and improved ways of spotting fires before they become uncontrolled wildfires.

6. Testing and Deploying Emerging Technologies

SDG&E is evaluating and incorporating new technologies and equipment into its overhead electric system. SDG&E's Electric Distribution Engineering Department is responsible for evaluating and creating new equipment and use standards for emerging and pre-commercial technologies. Using equipment failure data, the department determines which technologies should be incorporated into the SDG&E system and which could be improved prior to application. This department continually evaluates the many new types of technologies which may improve electric reliability and public safety and gives special attention to technologies that may contribute to SDG&E's fire-safety goals and objectives. As an example, SDG&E is applying more advanced fault-clearing algorithms to

⁷ SDG&E plans to install another seven (7) cameras on towers located in Cleveland National Forest; installation of these cameras is pending approval by the United States Forest Service.

improve the ability of the system to clear "wire-down" faults more quickly and which will serve to reduce the potential such faults might provide an ignition source.

7. Facility Inspection and Repair Program

In addition to adding, redesigning and replacing facilities and elements as described above, SDG&E has implemented more stringent monitoring and inspection programs in the Fire Threat Zone and Highest Risk Fire Area, intensifying our efforts to identify potential substandard system facilities and elements. As an example of these efforts, SDG&E is developing the use of pole-loading algorithms which more accurately calculate working loads and stresses. Post-construction surveys are beginning to occur using these calculations to confirm as-built construction matches engineering design. This area of study and change is undergoing continuous improvement to address new information, knowledge and situations. SDG&E coordinates these activities with the communications infrastructure providers which jointly use SDG&E's poles and facilities.

SDG&E also maintains a comprehensive outage database which is used for reliability measurement and reporting purposes. Correlations between outages and locations are analyzed to determine whether certain equipment is prone to outage or has the potential to be an ignition source. This analysis is then matched to weather and other environmental conditions. Where it is determined that certain types of hardware have higher incidents of failure and potentially a higher incidence rates for ignition, they are replaced or prioritized for replacement.

SDG&E is also in the process of conducting facility testing using three-dimensional light detection and ranging surveys in the Highest Risk Fire Area. This technology is being used to perform aerial scans of the sixty-nine kilovolt transmission system in the Highest Risk Fire Area on a three-year cycle. These surveys provide detailed depictions of terrain, vegetation and other obstacles in the vicinity of SDG&E's facilities. This data is processed and modeled by the SDG&E Power Line System Computer-Aided Design and Drafting technology to depict actual field conditions. The information produced through these efforts is used to ensure safe and proper clearances are met so as to reduce the potential for line faults occurring in the Highest Risk Fire Area. Where potential issues are discovered, SDG&E will address potential issues by September 1st, the calendar start of fire season, subject to permitting requirements and other exigencies and conditions.

8. Oversight of Activities in the Rural Areas

Early in 2010, a multi-disciplinary technical team of subject matter experts within SDG&E, named the "Reliability Improvements in Rural Areas Team" ("RIRAT"), was formed and tasked with (a) developing a multi-dimensional understanding of the complex fire-risk issue within the SDG&E service territory, (b) assessing the conditions which pose the greatest risks related to fire, (c) determining the level of risk mitigation that could be provided by various proposed projects, and (d) assigning priorities to capital and operating programs and projects that could address fire-related risks in the Fire Threat Zone. As is evident from the Fire Threat Zone and Highest Risk Fire Area maps attached to this Fire Prevention Plan, it is in these areas where the potential for uncontrolled wildfires, and potentially the greatest losses, is the highest. The RIRAT focuses its attention on facilities and activities in these areas so as to assure all prudent and cost-effective fire-prevention measures are promptly evaluated and implemented.

The RIRAT is led by the SDG&E Asset Management and Smart Grid Department and includes managers and engineers from the Asset Management and Smart Grid Projects Department, the Electric Transmission and Distribution Engineering Department, the Electric Regional Operations Department, and the Electric Finance and Operations Management Department.

The RIRAT, among other things, oversees the evaluation and implementation of the various fire-hardening activities described above.⁸ Its work is guided by the following specific goals and objectives:

- Improve the distribution system in the Fire Threat Zone and Highest Risk Fire Area;
- Develop statistical measures for assessing distribution-system performance relevant to fire-related risks so as to provide an understanding of the scope of the risks that must be addressed and develop metrics for measuring improvement;
- Identify and prioritize areas posing the greatest fire-related risks;
- Develop guidelines and a portfolio of solutions to minimize fire-related risks;

⁸ The Rural Area Team also oversees the design and implementation of operations, maintenance and inspection programs and activities in the San Diego backcountry. Those activities and programs are discussed in further detail later in this Fire Prevention Plan.

- Develop a multi-year plan for the rebuilding of circuits creating the greatest and/or most probable fire-related risks;
- Review and analyze all reports of “wire-down” occurrences; and,
- Use the “wire-down” analysis to identify causes and best solutions so as to minimize future occurrences and fire-related risks.

In order to meet their goals, the RIRAT adopted the following guiding principles:

- Utilize risk-based prioritizations to maximize risk-mitigation;
- Improve design specifications to reduce the potential for igniting fires;
- Consider and, to the extent prudent and cost-effective, employ technology-based solutions to reduce fire risks and improve overall system reliability;
- Prioritize system-rebuild efforts based on a matrix of available projects, considering the most important input factors such as the recent occurrence of a “wire-down”, wind and weather conditions, fire risks, values at risk, outage history, conductor type, condition of equipment, environmental conditions, and critical customers;
- Systematically consider and evaluate the following options:
 - Fire-hardening sections of circuits or individual circuit branches;
 - Undergrounding by traditional undergrounding or cable-in-conduit;
 - Adjusting protective equipment by revising settings, balancing loads, adding reclosers, replacing expulsion fuses with fault tamers, and/or reducing fuse size; and,
 - Employing new methods and/or technologies, such as spacer cables, wireless fault indicators, “off-grid” solutions, and Smart Grid technologies;
- Replace high-risk equipment based upon statistical analytics;
- Re-align circuit routings to avoid trees and dense vegetation or use tree guards and/or insulated aerial cables; and,
- Assess the costs and benefits of optional solutions for reasonableness.

The RIRAT oversees the evaluation and approval processes for the various system improvements and capital projects described above and specifically addresses system design and facilities from the perspective of minimizing fire-related risks in the rural areas included in the Fire Threat Zone and Highest Risk Area.

III. Operational Practices for Reducing the Risk of Ignition

Despite all the efforts SDG&E might take in designing, redesigning, improving, replacing, and fire-hardening various elements of its overhead electric system, there will be some remaining potential risk that SDG&E's facilities might be the source of ignition for a fire. To address these risks, SDG&E has designed and implemented a number of operations, maintenance and inspection programs directly addressing fire prevention and the mitigation of the effects of any fires that might occur.

A. System Management: Quality Assurance and Quality Control

SDG&E has enhanced its system-management programs so as to assure that, to the extent possible, SDG&E's overhead system, facilities and equipment are unlikely to become the source of ignition for a fire. These programs generally encompass inspection and maintenance functions and have been modified to focus on minimizing the probability that substandard, damaged or aging facilities will provide the ignition source for a fire. Inspection and repair of the SDG&E transmission and distribution systems have particularly intensified in the Fire Threat Zone and Highest Risk Fire Area. To that end, SDG&E performs a G.O. 165 type system maintenance patrol of the entire overhead electric system in the Fire Threat Zone on an annual basis. Safety related non-conformances identified in those patrols are scheduled for a follow up repair. These patrols are twice as frequent as that required of the overhead system in general. In addition, SDG&E has implemented Quality Assurance and Quality Control standards and programs throughout its service territory, with a special focus in the Highest Risk Fire Area during fire season.⁹ These proactive programs are designed to identify potential structural and mechanical issues before they become actual problems. Distribution facilities within the Highest Risk Fire Area are now inspected in detail, at minimum, on a three-year cycle and substandard facilities (*e.g.*, damaged equipment, missing equipment or hardware, overgrown vegetation, *etc.*) are noted during these inspections and trigger the issuance of a repair work-order. Where the facility in need of repair is owned by a party other than SDG&E, *e.g.*, by a communication infrastructure provider, SDG&E will issue a notice to repair to the facility owner and work with the facility owner to ensure necessary repairs are completed promptly. SDG&E's operational goal, subject to permitting

⁹ The Quality Assurance and Quality Control program augments the five-year inspection cycle imposed under the provisions of Commission General Order 165.

requirements and other exigencies and conditions, is to complete all facility and equipment repairs before September 1st of each year.¹⁰

Annual adjustments to the Highest Risk Fire Area map, if any, are also reflected in the scope of the Quality Assurance and Quality Control program.

The SDG&E Transmission Quality Assurance and Quality Control program is similar in nature to its distribution counterpart. Transmission lines within the Highest Risk Fire Area, subject to any annual adjustments to the Highest Risk Fire Area boundaries that might be made based on updated data, are inspected on a three-year cycle.¹¹ Matters of concern are identified for repair and SDG&E makes best efforts, subject to permitting requirements and other exigencies and conditions, to complete all repairs within the Highest Risk Fire Area by September 1st, the calendar start of fire season.

B. Enhanced Vegetation Management and Clearance Program

SDG&E currently maintains records for the over 400,000 trees located near its power lines. Almost 100,000 of these trees are located within the SDG&E Highest Risk Fire Area. All of the 400,000 trees in SDG&E's database are monitored using known species and specimen growth rates, with additional consideration given to the amount of rainfall occurring during periods affecting overall tree growth. Each tree is visited by a staff arborist on a periodic cycle to ensure that every tree is trimmed according to accepted standards and clearances. A second inspection and corresponding tree-hazard evaluation is performed for each tree in the Highest Risk Fire Area. To the extent unsafe clearances may exist, an order to clear vegetation is issued and trimming is completed prior to September 1st of each year. These activities ensure safe minimum vegetation clearances are achieved prior to the fire season.

In addition, SDG&E developed and implemented a system wide Tree Safety Program. This program assists customers in the selection of the tree species and planting locations which will minimize interference with nearby power lines and facilities. SDG&E also offers free tree replacements in the event that an existing tree has grown into power lines and should be removed rather than trimmed. Notably, SDG&E has, for the tenth consecutive year, been recognized by the

¹⁰ September 1st marks the beginning of the "fire season", although the highest risks of and from fire in the SDG&E service territory typically occur in October and November.

¹¹ The three-year inspection cycle for transmission facilities coincides with the normal cycle specified in SDG&E's Transmission Maintenance Practice manual.

National Arbor Day Foundation as a "Tree Line USA" utility company in recognition of our "best practices" combining worker education and training, public outreach, quality tree care, and system reliability.

Finally, SDG&E notes that we manage over 35,000 poles within the CalFIRE jurisdictional areas that have been designated as bearing "non-exempt" attachments.¹² For these poles within the CalFIRE jurisdiction are poles, that bear these "non-exempt" attachments, SDG&E is required to perform "pole brushing", that is, clearing all vegetation within a ten-foot radius of the pole. For these poles however, SDG&E has increased the minimum clearing from the required ten-foot radius to eleven feet so as to decrease the risk of ignition even further. SDG&E is also working to reduce the number of non-exempt power line components by replacing such equipment, where feasible, with exempt equipment, which should also reduce the potential for pole attachments to become an ignition source.

C. Coordination with Communications Infrastructure Providers

SDG&E has developed and rolled out a new web-based communication conduit to simplify the recordkeeping for, and approval, inspection and repair of, pole attachments owned by Communications Infrastructure Providers. Named the "Telecommunication Equipment Attachment Management System" ("TEAMS"), the system was placed in operation in October of 2012. TEAMS provides a direct communication link between SDG&E and Communications Infrastructure Providers and a shared-recordkeeping functionality. There are four key benefits provided by TEAMS. First, TEAMS enables Communications Infrastructure Providers to file pole attachment applications on-line – tracking of these applications and accompanying documents can now be performed electronically. This provides the baseline data necessary for SDG&E to monitor the equipment and resulting working loads placed on SDG&E facilities. Second, all attachment applications can be delivered and tracked by the applicant and SDG&E. Third, this system is also used for requesting and tracking requests for pole transfers and other transactions involving changes to equipment on jointly owned poles with communications-related attachments. Finally, if during an inspection SDG&E discovers any pole attachment to be substandard and/or in need of repair, notices and the tracking of repairs will be done through TEAMS. This provides both SDG&E and the Communications Infrastructure Providers with electronic records

¹² These attachments are designated as "non-exempt" by virtue of posing some potential risk for becoming an ignition source.

of the actions taken by both to assure overhead facilities are in good repair and less likely to provide a source of ignition for a fire.

D. Workforce Training and Field Practices

SDG&E believes that an important line of defense against the ignition of fires is a well-trained and alert workforce. Internally, SDG&E has created a culture of fire prevention. To that end, SDG&E has adopted an extensive set of work rules and complementary training programs designed to minimize the likelihood SDG&E's facilities or field work will provide the source of ignition for a fire. Those rules and training programs are in large part embodied in SDG&E Electric Standard Practice No. 113.1 ("ESP 113.1") which specifically addresses wildland fire prevention and fire safety. ESP 113.1 was developed by SDG&E's expert team of Fire Coordinators based on their experience in fire behavior, fire prevention and firefighting techniques. ESP 113.1 also incorporates principles and concepts drawn from various federal, state and local protocols and standards addressing wildland fire prevention and suppression.

ESP 113.1 describes the conditions under which the threat of fire is considered high and the changes in field practices and resources which will be implemented as the threat increases. These changes affect work rules, equipment which will be made available to work crews under different conditions, and even worker attire. ESP 113.1 specifies minimum training requirements and annual refresher requirements for all SDG&E and contract personnel working in the Fire Threat Zone and Highest Risk Fire Area. The work rules and training also apply to personnel working in SDG&E's Electric Distribution Operations and Electric Grid Operations centers.

As an essential part of ESP 113.1, SDG&E has adopted and implemented the principles of the Incident Command System. This system provides a structure for disciplined communications and decision-making under the threat of fire as well as during fire emergencies. SDG&E field supervisors are assigned varying levels of on-scene command responsibilities in terms of coordinating and managing the SDG&E response to threat and emergency conditions. Training in the Incident Command System protocols and responsibilities is a key element of the annual training conducted by SDG&E.

IV. Mitigating the Threat of Fire: Awareness and Readiness

A. Situational Awareness

Although the risk of fire is a year-round reality, there are certain recurring environmental and weather conditions, particularly during the late summer and early fall, when the risks of and from fire, particularly from uncontrolled wildfires, in the SDG&E service territory are abnormally high and the dangers most severe. SDG&E's fire-prevention and risk-mitigation activities begin with intensive data gathering and data analysis so that, if and when these abnormal and dangerous conditions are anticipated or occur, SDG&E is prepared to mobilize personnel and resources to abate, mitigate and respond to these conditions and any potential fire threats.

SDG&E has developed extensive, high-resolution weather databases which are used to identify those areas where the threat of and from uncontrolled wildfire is the highest and/or most dangerous. The areas which SDG&E monitors most closely are shown in the Fire Threat Zone and Highest Risk Fire Area maps – these areas are distinguished by the coincidence of high winds and flammable vegetation. SDG&E's weather databases are constantly updated using weather data provided by a number of sources, including the United States National Weather Service, local airports, and SDG&E's proprietary network of 145 weather stations located primarily in the Fire Threat Zone.¹³ SDG&E's private meteorological network alone provides over 120,000 data points per day.¹⁴

SDG&E has two (2) full-time degreed meteorologists on staff. Their responsibilities include analyzing the historical databases and, importantly, monitoring incoming data in real-time. They also provide a detailed daily forecast of weather conditions relevant to SDG&E's operations. Their forecasts, a combination of heat, humidity, wind, and other conditions, are combined into an "Operating Condition" assessment, which tracks the potential for fires occurring in any region of the SDG&E service territory. There are four (4) Operating Conditions used for these purposes:

- **Normal Condition:** This condition is declared across the service territory when it has been determined by the SDG&E meteorologists and Fire Coordinator team that the burn environment is not conducive for wildfires within the SDG&E service territory;

¹³ The location of SDG&E's weather stations is shown on the Fire Threat Zone and Highest Risk Fire Area map attached as an appendix to this Fire Prevention Plan.

¹⁴ SDG&E makes its weather data available to public agencies and the general public free of charge through several popular media outlets, including the Internet.

- **Elevated Condition:** This condition is declared across the service territory when it has been determined by the SDG&E meteorologists and Fire Coordinator team that the burn environment has become conducive for wildfires within the SDG&E service territory;
- **Elevated Wind Condition:** This condition is declared for specific operating districts and regions when it has been determined by the SDG&E meteorologists and Fire Coordinator team that a combination of high winds, low relative humidity, and the burn environment will create critical fire weather conditions; and,
- **Red Flag Warning Condition:** Red Flag Warning Condition is declared by the National Weather Service when high winds and low relative humidity are forecasted to occur for an extended period of time. In elevating the Operating Condition to this level, the SDG&E staff meteorologists would be echoing the declaration.

Depending on the condition reported and broadcast by the meteorological staff, various operational changes and rules appropriate to each condition will be triggered and implemented. A table summarizing the four conditions and the associated operational responses to each is shown immediately below:

Operating Chart for Highest Risk Fire Area

NORMAL CONDITION	ELEVATED CONDITION Based on Fire Indices (Starting by September 1 or Earlier)	ELEVATED WIND CONDITION Based on Fire Indices and High Winds	RED FLAG WARNING CONDITION
<p><i>No change to reclosing policy.</i></p> <p><i>Line will be tested by recloser action.</i></p>	<p><i>All reclosing functions will be de-activated.</i></p> <p><i>For 2012, this occurred on June 19.</i></p>	<p><i>All reclosing functions will be de-activated.</i></p> <p><i>Enable Sensitive Relay Settings at direction of EDO</i></p>	<p><i>All reclosing functions will be de-activated.</i></p> <p><i>Enable Sensitive Relay Settings at direction of EDO</i></p>
	<p><i>Patrol the line before energizing</i></p> <p><i>Strategic Use of Pulse Closers Permitted</i></p>	<p><i>Patrol the line before energizing</i></p> <p><i>Activate Crew Deployment Play by District</i></p> <p><i>Utility Wildfire Prevention Team on Standby (Staged and Available)</i></p>	<p><i>Patrol the line before energizing</i></p> <p><i>Activate EOC and Crew Deployment Plan</i></p> <p><i>Utility Wildfire Prevention Team on Standby (Staged and Available)</i></p> <p><i>If high winds are present or projected, field crews will be observing for potentially hazardous conditions.</i></p> <p><i>One or more circuits may be de-energized for public safety.</i></p>

The daily weather forecast and Operating Condition are broadcast by electronic media to personnel whose activities are affected by the declaration of the Operating Condition – the forecast, particularly when the threat of fire is high or rising, will be updated and rebroadcast as conditions warrant and as the staff meteorologists determine is appropriate. The forecast is broadcast in real-time to a large audience of SDG&E employees, including but not limited to those responsible for system operations and control, district field operations, transmission and substation operations, and communications. Senior and middle management also receive these weather updates. Personnel receiving these weather forecasts are trained to adjust their activities, duties and priorities based upon the Operating Condition reported by the staff meteorologists.

Generally, as actual or forecasted wind speeds, measured in terms of both sustained winds (the average wind speed across ten-minute intervals) and wind gusts (the highest wind speed occurring during a three-second period within a ten-minute interval), increase, the Operating Condition will change (or “be elevated”), from “Normal” to “Elevated Condition” or “Elevated Wind Condition” or “Red Flag Warning Condition”, depending on environmental and weather conditions and the strength of the winds being experienced or forecasted. With each step-change in the Operating Condition, personnel are placed on appropriate levels of alert. In addition, the level of system monitoring and, ultimately, system operations and activities are elevated according to the prevailing Operating Condition. Most importantly, as wind speeds increase, SDG&E deploys an increasing number of field crews, troubleshooters and Utility Wildfire Prevention Teams to areas with the highest winds and where the greatest threat of fire exists so as to increase the probability that fires will be detected early and a response will occur as soon as possible. More information regarding the nexus between the situational awareness activities of the SDG&E meteorological staff and system and field operations is provided later in this Fire Prevention Plan.

B. The SDG&E Emergency Operations Center

In the event the National Weather Service declares a Red Flag Warning, the SDG&E meteorologists will elevate the warning broadcast to SDG&E personnel to the highest level of alert. Red Flag Warnings are typically issued when relative humidity is at or below fifteen percent (15%) and sustained winds are expected to reach twenty-five miles-per-hour (25 mph) or higher and/or frequent wind gusts exceeding thirty-five miles-per-hour (35 mph) are expected for a duration of six or more hours. A Red Flag Warning will also be issued under “dry lightning conditions”, where a lightning event is expected in the absence of enough

precipitation to wet potential fuels which are considered critically dry. Upon the declaration of a Red Flag Warning, SDG&E will activate the Emergency Operations Center at the appropriate levels.

Because Red Flag Conditions present threats to the SDG&E electrical system and its component facilities and equipment, specific members of SDG&E management and operating departments are placed on alert when these conditions are present and the National Weather Service has issued a Red Flag Warning. Upon such a declaration, these senior managers and operating personnel are called upon to appropriately man the SDG&E Emergency Operations Center, a secure and dedicated facility which serves as a command center for SDG&E operations under high-threat conditions. The activation of the Emergency Operations Center assures that appropriate decision makers and experts are assembled together, providing for the close monitoring of the electrical system and operations by all involved departments and disciplines. As the situation changes, the Emergency Operations Center personnel will take appropriate and timely actions as necessary in order to protect the public safety and defend against the threat that SDG&E's electrical facilities will become a source of ignition.¹⁵

C. The Fire Potential Index

SDG&E has developed a comprehensive assessment, known as the "Fire Potential Index", that is used as a tool for making operational decisions which would reduce fire threats and risks. This tool converts environmental, statistical and scientific data into an easily understood forecast of the short-term fire threat which could exist for different geographical areas in the SDG&E service territory. The Index is generated for a seven-day forecast period and provides SDG&E personnel and threatened communities time during which they may plan and prepare accordingly.

The Index reflects key variables such as the state of native grasses across the service territory ("green-up"), fuels (ratio of dead fuel moisture component to live fuel moisture component), and weather (sustained wind speed and dew point depression). Each of these variables is assigned a numeric value and those individual numeric values are summed to generate a Fire Potential value from zero (0) to sixteen (16), each of which expresses the degree of fire threat expected for each of the seven days included in the forecast. The numeric values are classified as "very low", "low", "moderate", "high", "very high", and "extreme".

¹⁵ Such actions may include those authorized by statute and CPUC decisions, including D.09-09-030 as modified by D.12-02-024.

The state of native grasses, or "Green-Up Component", of the Fire Potential Index is determined using satellite data for various locations. This component is rated on a 0-to-5 scale ranging from very wet (or "lush") to very dry (or "cured"). The scale is tied to the NDVI Relative Greenness Scale, which ranges from 0 to 120,¹⁶ as follows:

FPI Green-Up Component

Very Wet/Lush: 85 to 120	70 to 85	60 to 70	50 to 60	35 to 50	Very Dry/Cured 0 to 35
0	1	2	3	4	5

The Fuels Component of the Fire Potential Index measures the overall state of potential fuels which could support a wildfire. Values are assigned based on the overall state of available fuels (dead or live) for a fire using the following equation:

$$FC = FD / FI$$

Where FC represents "Fuels Component" in the scale below;

And FD represents Fuel Dryness Level (using a 1-to-3 scale);¹⁷ and,

And FI represents Live Fuel Moisture (percentage).

The product of this equation represents the fuels component that is reflected in the Fire Potential Index as follows:

FPI Fuels Component

¹⁶ The Normalized Difference Vegetation Index ("NDVI") is a simple graphical indicator that can be used to analyze remote sensing measurements, typically but not necessarily from a space platform, to assess whether the target area under observation contains live green vegetation or not. More information on the NDVI scale is available at the following address: http://en.wikipedia.org/wiki/Normalized_Difference_Vegetation_Index.

¹⁷ These values are taken from the Southern California Geographic Area Coordination Center, an interagency support center for fire protection and suppression. More information regarding this agency can be found at the following address: <http://gacc.nifc.gov/oscc/>.

Very Wet					Very Dry
1	2	3	4	5	6

The weather component of the Fire Potential Index represents a combination of sustained wind speeds and dewpoint depression as determined using the following scale:

FPI Weather Component

Dewpoint/Wind	≤4 knots	5 to 9	10 to 14	15 to 19	20 to 24	>24 knots
>50°F	2	3	3	4	5	5
40°F to 49°F	2	2	3	3	4	5
30°F to 39°F	1	2	2	3	3	4
20°F to 29°F	1	1	2	2	3	3
10°F to 19°F	0	0	1	1	1	1
□10°F	0	0	0	0	0	0

The individual numeric values representing the three variables reflected in the Fire Potential Index, shown above, are combined and placed on the following scale:

Fire Potential Index

Very Low	Low	Moderate	High	Very High	Extreme
□7	7 or 8	9 or 10	11 or 12	13 or 14	15 or 16

The Index was developed by a team made up of SDG&E meteorologists, fire coordinator and statistical analysts. The team has validated the Index values and their usefulness by recreating historical values for the past ten (10) years. The historical results bore a very strong correlation to actual fire events in terms of the severity of past fires and, in particular, provided very accurate information as to when the risks of uncontrolled and large-scale wintertime fires were high. The Index is a relatively new product, and, over time, SDG&E expects to tie proactive and reactive operational practices and measures to the Index values, with the further expectation that SDG&E will be able to reduce the likelihood its facilities and operations will be the source of ignition for a fire during times when the risk of fire as measured by the Fire Potential Index is high, very high or extreme.

D. Crew Mobilization and Deployment Strategy

During an Elevated Wind Operating Condition or Red Flag Warning Condition, the management of the SDG&E Electric Distribution Operations and Electric Grid Operations centers work to coordinate the assignment of appropriate and needed resources to each of the affected regional operating districts. At minimum, Electric Troubleshooters and personnel from the Utility Wildfire Prevention Team are made available for immediate response to address fire threats or events. If the event is more severe, additional resources will be coordinated between and assigned from Electric Distribution Operations, Electric Grid Operations, Electric Regional Operations, Construction Services, and Kearny Substation and Transmission Operations Center to manage the event. Field personnel may be assigned to observe an area forecasted to experience the most adverse weather conditions – these personnel are under instructions to report flying debris, vegetation damage, or significant conductor movement. Based on these field observations, SDG&E deploys appropriate resources to address the fire threats posed by these conditions.

E. Field Patrols

Under Elevated, Elevated Wind and Red Flag Warning Conditions, SDG&E perform an appropriate patrol of any circuit within the SDG&E Threat Zone suffering a forced outage. Qualified electrical workers are dispatched to inspect the circuit, determine the cause of the outage, and evaluate the physical integrity of the circuit. Restoration of service is subject to this inspection and evaluation. Upon the appropriate evaluation, restoration will commence when repairs are completed and/or there is no longer a threat to public safety or the electric system. In some cases and weather permitting, field personnel may be positioned to observe and test the affected circuit.

Training and refresher drills for field patrols are conducted annually and are designed to exercise the assembly of Patrol Teams and the communication hierarchy of the SDG&E Incident Command System. These drills ensure effective management of the Restoration Patrols and disciplined communications between Patrol Teams, Patrol Leaders, Fire Coordinators, and Incident Commanders.

V. Fire Suppression and Recovery

When fire risk is high and a wildland fire occurs, SDG&E will mobilize its available resources to assist in coordinating the suppression of the fire and in post-event recovery activities. In many instances, these resources are made available to the public agencies with responsibility for fire suppression and recovery.

A. Fire Coordination Personnel

SDG&E employs a full-time staff of Fire Coordinators and contracts for additional resources and personnel on an as-needed, project-by-project basis. The four Fire Coordinators currently on staff have over a century of firefighting experience and are experts in fire behavior, fire prevention and firefighting techniques. The Fire Coordinators serve as the direct link between SDG&E and emergency-response agencies. They also serve as the single point of contact for the fire agency Incident Command System, provide periodic updates to fire emergency personnel and SDG&E personnel, establish radio and communications assignments for every fire event, assist in the coordination of activities related to de-energizing and re-energizing power lines, and update on-scene personnel, control centers, service dispatch, and the SDG&E operations centers as to the status of each incident. The Fire Coordinators are active in professional forums, seminars and training throughout the service territory to ensure state-of-the-art fire practices are

incorporated into SDG&E operations and practices. The Fire Coordinators also participate in engineering and operational meetings to advise SDG&E personnel regarding fire threats and prevention.

The Fire Coordinators also share information with the firefighting agencies within the SDG&E service territory and, on a rotating basis, provide those agencies with electrical and gas safety training.

B. Firefighting Assets and Resources

1. Utility Wildfire Prevention Team

SDG&E has contracted for wildland fire-suppression engines and trained firefighting personnel. Five engines are provided to SDG&E throughout the fire season, from September 1st through November 30th of each year, and are available to SDG&E on an on-call basis for the other months of the year. These resources are dispatched with work crews during days on which the threat of fire is high. Prior to the commencement of the day's work, firefighting personnel provide instruction and advice specifically addressing fire risks and the potential mitigation and prevention measures the crews should observe in order to eliminate or reduce the likelihood of an ignition. The firefighting crews also pre-deploy hose lines and tools as a precautionary measure and monitor the work performed by the SDG&E crews.

In the event of an ignition, the firefighting personnel have the equipment, skills and ability to respond and extinguish fires quickly.

When the fire risk is very high, SDG&E deploys additional engines as needed pursuant to a proactive staging plan triggered by the declaration of "Elevated Wind Conditions" and "Red Flag Warning Conditions". These resources are strategically placed throughout the service territory to be available as needed.

2. Aviation Services Department

SDG&E recently added an Aviation Services Department to its organization. This department is responsible for contracting aviation assets and personnel, planning, supporting and managing day-to-day aviation activities, measuring aerial job performance, and supporting fire-suppression activities. With respect to its fire-suppression responsibilities, the department coordinates the provision of SDG&E aerial resources to firefighting efforts. The department also oversees SDG&E's

contributions to and participation in the local Aerial Firefighting Protection Fund in collaboration with the San Diego Fire Department and the San Diego County Office of Emergency Services.

SDG&E has also contracted with Erickson Air-Crane for the provision of a Type 1 firefighting helicopter from September 1st through November 30th through the year 2016. This contract is under the supervision of the Department.

3. The Industrial Fire Brigade

SDG&E has contracted a full-time Industrial Fire Brigade. For the next three years, the Brigade will be on duty and available to SDG&E on an around-the-clock basis. The Brigade is made up of a Brigade Leader and three (3) shifts consisting of a Fire Captain, Fire Engineer, and two (2) firefighters. The Brigade is specially trained in fighting fires involving electrical equipment and flammable liquids. The Brigade members are housed in facilities located near the geographical center of the SDG&E service territory and are fully equipped to handle utility-related fire emergencies.

The Brigade is equipped with two (2) portable trailers, each provisioned with 300 gallons of Class B Alcohol Resistant firefighting foam, 500 pounds of PKP Dry Chemical extinguishing agent, a 500 gallon-per-minute monitor, and two self-educuting handlines designed to work with hydrants or other mobile fire apparatus. Recently, SDG&E purchased two (2) additional firefighting trailers. These new trailers are located in Boulder City, Nevada, near the SDG&E Desert Star Power Plant and at an Imperial County Fire Station close to the SDG&E Imperial Valley Substation.

The Brigade is also responsible for the development of comprehensive pre-emergency response plans for each SDG&E facility. These plans will be developed for SDG&E's high-values assets first, including SDG&E's power plants, peaker stations, and extra-high-voltage substations. These plans are designed to improve emergency response at each of these facilities significantly.

4. Miscellaneous Assets

SDG&E maintains thirty-four portable emergency generators which will be deployed on an as-available basis to customer locations to provide temporary power during electrical outages. These generators will generally be made available to providers of essential services as a first priority but could be made

available, if available, to other customers upon request and on a case-by-case basis.

SDG&E has been proactive in developing programs and partnerships which significantly improve emergency-event communications both internally and in cooperation with emergency-services agencies. In this regard, SDG&E has acquired Mobile Field Command Trailers and satellite phone booths for forward deployment and to assure uninterrupted essential communications during emergencies. SDG&E is also working on an initiative to create an Area Situational Awareness for Public Safety Network (or "ASAPnet") which will be designed and deployed to provide internet connectivity to and between more than seventy (70) fire stations throughout the San Diego County backcountry.

C. Recovery Activities

At the end of emergency events, the SDG&E Emergency Operations Center conducts regular tabletop and functional training exercises and debriefs on potential issues ranging from cybersecurity to catastrophic fires. Debriefs are conducted following each exercise and activation of the Emergency Operations Center.

Also, SDG&E employees participate in a number of volunteer and charitable activities on an ongoing basis – this participation expands dramatically following local disasters. These activities include providing human, financial and other resources to the American Red Cross, San Diego County Recovery, the San Diego Burn Institute, and many other worthy organizations.

VI. Community Outreach and Public Awareness

SDG&E has created a multi-level approach to community education and outreach as our contribution to public awareness of fire threats, fire prevention and emergency preparedness. The key elements of this approach are described below.

A. Fire Safety Stakeholder Council

SDG&E frequently invites community leaders and the public at-large to participate in a collaborative fire-safety process. About forty (40) stakeholders, including representatives of local school districts, water districts, disability rights advocates, consumer groups, and fire agencies, have been working with SDG&E to develop a

joint fire-prevention and emergency-action plan. This collaboration has already produced more than 100 potential solutions aimed at preventing the occurrence of major fires. SDG&E is implementing many of the solutions identified by these stakeholders, including deactivating automated reclosers, hardening its overhead electrical system through the use of steel poles and larger conductors, and undergrounding portions of the backcountry electrical system where feasible.

B. Partnering with Firefighting Agencies

SDG&E has partnered with the San Diego County Fire Chiefs' Association to address a range of activities. The Association includes fifty-three (53) fire agencies, fire-safe councils, Community Emergency Response Teams and other community organizations. Among the activities addressed through this partnership are, including but not limited to:

- Participation in coordinated multi-agency preparedness and emergency events;
- Support of the annual May County Wildland Drill;
- Participation in Fire Station Open Houses and Fire Safe Councils, prior to and through the fire season;
- The provision and underwriting of grants by SDG&E to support Volunteer Fire Fighters, CalFIRE Public Information Officer Command Vehicles, Burn Institute programs, and the San Diego Kids Fire Safety Program;
- Fire-safety media campaigns in conjunction with the American Red Cross and local television station KUSI-TV; and,
- The "Prepare San Diego Partnership" and Sheltering Memorandum-of-Understanding executed by and with the American Red Cross.

SDG&E also chairs the California Utilities Emergency Association, a collaboration between utilities, emergency services agencies and the California Emergency Management Agency.

C. Community Partnerships

SDG&E is proud to support non-profit organizations whose programs promote emergency preparedness and safety at home and in our communities. In 2012, SDG&E provided funds to charitable organizations committed to regional and local emergency preparedness and fire safety, such as 2-1-1 San Diego, the American

Red Cross, and the Burn Institute, plus dozens of volunteer fire departments, Community Emergency Response Teams and Fire Safe Councils.

SDG&E provides regular communications to residents and businesses located in the Fire Threat Zone and Highest Risk Fire Area. These fire-safety and emergency communications include, but are not limited to, the following:

- Customer education events, public participation meetings and backup generator safety workshops;
- Informational and emergency preparedness mailings to customers in the Highest Risk Fire Area;
- Educational advertising campaigns focusing on SDG&E's preparations for the fire season and the preparations SDG&E's customers should make for emergencies;
- Educational information disseminated through the Energy Notes newsletter distributed with customer billings;
- Distribution of a co-branded "newsletter" with the American Red Cross, the San Diego Office of Emergency Services, and the County Fire Chiefs Association;
- Distribution of the "Z-Card" which provides formatted emergency information that easily folds and fits in an automobile glove box or emergency kit;
- Distribution of "refrigerator magnets" bearing important emergency information;
- The provision of weather information and system-outage status on SDGE.com;
- Dissemination of information regarding emergency-preparedness events via social media such as Twitter and Facebook;
- Opt-in campaign offering customers electronic-mail access to safety checklists and fire-safety videos;
- Publication of information for SAFE San Diego Education and Outreach events in the community following an emergency.

In addition to routine outreach and communications, SDG&E intensifies its effort to communicate with customers when fire-threat conditions are elevated or extreme. SDG&E has instituted an early warning system advising customers that a Red Flag Warning has been declared by the National Weather Service and dangerously high winds are expected. SDG&E also opens communications with local water districts, telecommunications infrastructure providers, the San Diego County Office of Education, the San Diego County Office of Emergency Services,

and the American Red Cross as soon as possible following the declaration of a Red Flag Warning. SDG&E assembles a team including members from Commercial and Industrial Services, SDG&E's Meteorological Department and SDG&E's Electric Distributions Operations center to provide updates on the status of the SDG&E system and weather conditions.

As alert conditions are elevated, SDG&E also contacts, directly and indirectly, disabled customers and Medical Baseline (MBL) customers. Under severe threats of emergencies, where SDG&E cannot make contact with these customers via our outbound-dialer system, SDG&E will send field personnel to make personal contact with these customers and, failing all else, to leave door hangers alerting the customer of the situation.

D. Fire Preparedness Website

SDG&E maintains a publicly accessible website focused on safety, including gas safety, electric safety, fire safety, tree safety, emergency preparedness, generator safety, and outage information. SDG&E Emergency Preparedness Brochures, Z-Cards, radio spots, print advertisements, and social media postings via Facebook and Twitter have been utilized to distribute and provide links to SDG&E's emergency preparedness and safety website:

<http://www.sdge.com/safety/fire-safety/proactive-approach-fire-prevention>

Additional fire-related websites supported and maintained by SDG&E are accessible using the following addresses:

- Emergency Preparedness web pages: <http://www.sdge.com/safety>
- Weather and Outage web pages: <http://www.sdge.com/tools/windspeed-dashboard>

E. Fire Mitigation Funds

In addition to providing various fire-prevention and -preparedness grants as described above, SDG&E funds two fire-mitigation programs as a part of the Sunrise Power Link Project. These programs, known as the "Powerline Firefighting Mitigation Fund" and the "Defensible Space and Structure Hardening Grants Fund", are operated subject to agreements with various firefighting agencies whose jurisdictions include lands along the Sunrise Power Link transmission corridor.

The Powerline Firefighting Mitigation Fund was used to provide a lump sum to each of the seven fire agencies with jurisdiction along the transmission line route. Each agency received \$556,524, for a total disbursement of \$3.9 million – these funds were used to purchase new fire trucks and communications equipment, increase fire patrols, and fund additional personnel during the fire season. The agencies receiving these funds include CalFIRE, the federal Bureau of Land Management, the County of San Diego, the City of San Diego Fire & Rescue Department, the Alpine Fire Protection District, the Lakeside Fire Protection District, and the San Diego Rural Fire Protection District.

The Defensible Space & Structure Hardening Grants Program was implemented in 2012 and will remain in place as long as the Sunrise Power Link is in service. A grants contractor, Environmental Resource Solutions (ERS), has been hired and is implementing a Public Education and Outreach Program for eligible property owners, developing the grant application website and other program requirements. The program provides funding for the creation and maintenance of defensible space around homes in close proximity to the Sunrise Power Link. This defensible space will bring those homes into with compliance with various fire codes so as to assist firefighters in minimizing structure and property damage. These funds may also be used to fire-harden structures by retrofitting rooftops with fire-resistant materials, installing fire shutters and double-pane windows, cave boxing, and removing and/or replacing wood fencing and/or decks. SDG&E annually provides \$2.8 million (2008\$) to fund the program.

Appendix A

2012 Map of SDG&E Fire Threat Zone, Highest Risk Fire Area And Meteorological Network

